


Load Test Result (MCS)

Bedrijf: 2Bro-Trading B.V.
 Site Code _____
 Province _____



Test Date: 27-8-2024 07:58:25
 Test Time: 04:21:43 / 05:00:00
 Serie nummer: 200008017A

Brand	EMROL	Volt.	80	Ah	775	Cells	40	Standby Volt.		Type	5PzS775	Year/Manuf.	04/12/2020	Ambient Temp.	
-------	-------	-------	----	----	-----	-------	----	---------------	--	------	---------	-------------	------------	---------------	--



Index	Method	Pulse	Setup Time	Elapsed Time	Setup Volt	Max Volt	Min Volt	Setup Amp	AH	Temperature	%
0	Discharge		05:00:00	04:21:43	68.0	86.6	68.0	155.0	-675.4	0	-86
04:21:43											